

CATEGORY:

BOILER/HEATER < 5 MMBTU

BACT Size: Small Emitter BACT (PTE < 10 lb/day)

BOILER

BACT Determination Number: 135	BACT Determination Date: 1/25/2017
---------------------------------------	---

Equipment Information

Permit Number: N/A -- Generic BACT Determination
Equipment Description: BOILER
Unit Size/Rating/Capacity: >= 75,000 Btu/hr and < 2.0 MMBTU/hr fired on LPG
Equipment Location:

BACT Determination Information

ROCs	Standard:	Good Combustion Practices
	Technology Description:	
	Basis:	Achieved in Pactice
NOx	Standard:	77 ppm for < 400,000 Btu/hr; all others 30 ppm
	Technology Description:	Low NOx burner with good combustion practices
	Basis:	Achieved in Pactice
SOx	Standard:	Good Combustion Practices
	Technology Description:	
	Basis:	Achieved in Pactice
PM10	Standard:	Good Combustion Practices
	Technology Description:	
	Basis:	Achieved in Pactice
PM2.5	Standard:	Good Combustion Practices
	Technology Description:	
	Basis:	Achieved in Pactice
CO	Standard:	400 ppm >= 400,000 Btu/hr; others good combustion
	Technology Description:	Low NOx burner with good combustion practices
	Basis:	Achieved in Pactice
LEAD	Standard:	
	Technology Description:	
	Basis:	

Comments: All units listed ppm are ppmvd corrected to 3% O2

District Contact: Joe Carle Phone No.: (916) 874 - 4838 email: jcarle@airquality.org



BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION

DETERMINATION NO.: 135
DATE: 1/25/17
ENGINEER: Joe Carle

Category/General Equip Description: Boilers/Heaters – LPG
Equipment Specific Description: Boilers/Heaters Greater or Equal to 75,000 BTU/hr and Less than 2.0 MMBTU/hr, Fired on LPG
Equipment Size/Rating: Small Emitter BACT (PTE < 10 lb/day)
Previous BACT Det. No.: 112

This BACT determination will update Determination #112 for boilers/heaters greater or equal to 75,000 BTU/hr and less than 2.0 MMBtu/hr, fired on Liquid Petroleum Gas (LPG/Propane). The Determination #112 did not consider differences in LPG/propane and natural gas combustion burner technology and rules applicability at various districts pertaining to units fired on natural gas only. This BACT determination will clarify those differences.

BACT ANALYSIS

A: ACHIEVED IN PRACTICE (Rule 202, §205.1a)

The following control technologies are currently employed as BACT for boilers/heaters greater or equal to 75,000 BTU/hr and less than 2.0 MMBTU/hr, fired on LPG/propane fuel, by the following air pollution control districts:

District/Agency	Best Available Control Technology (BACT)/Requirements
US EPA	<p><u>BACT</u> Source: EPA RACT/BACT/LAER Clearinghouse</p>
	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr
	VOC N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
	NOx N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
	SOx N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
	PM10 N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
	PM2.5 N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
	CO N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
	<p><u>RULE REQUIREMENTS:</u> None</p>

District/Agency	Best Available Control Technology (BACT)/Requirements														
ARB	<p><u>BACT</u> Source: ARB BACT Clearinghouse</p> <table border="1" data-bbox="440 411 1468 722"> <tr> <td colspan="2" data-bbox="440 411 1468 457">For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr</td> </tr> <tr> <td data-bbox="440 457 553 499">VOC</td> <td data-bbox="553 457 1468 499">N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td data-bbox="440 499 553 541">NOx</td> <td data-bbox="553 499 1468 541">N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td data-bbox="440 541 553 583">SOx</td> <td data-bbox="553 541 1468 583">N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td data-bbox="440 583 553 625">PM10</td> <td data-bbox="553 583 1468 625">N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td data-bbox="440 625 553 667">PM2.5</td> <td data-bbox="553 625 1468 667">N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td data-bbox="440 667 553 722">CO</td> <td data-bbox="553 667 1468 722">N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> </table> <p><u>RULE REQUIREMENTS:</u> None</p>	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr		VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr															
VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
SMAQMD	<p><u>BACT</u> Source: SMAQMD BACT Clearinghouse</p> <table border="1" data-bbox="440 947 1468 1419"> <tr> <td colspan="2" data-bbox="440 947 1468 993">For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr</td> </tr> <tr> <td data-bbox="440 993 553 1073">VOC</td> <td data-bbox="553 993 1468 1073">Good combustion practice; Use of natural gas or LPG if natural gas is not available.</td> </tr> <tr> <td data-bbox="440 1073 553 1152">NOx</td> <td data-bbox="553 1073 1468 1152">Pool/spa heaters: 55 ppmvd at 3% O₂ All other boilers/heaters: 20 ppmvd at 3% O₂</td> </tr> <tr> <td data-bbox="440 1152 553 1232">SOx</td> <td data-bbox="553 1152 1468 1232">Good combustion practice; Use of natural gas or LPG if natural gas is not available.</td> </tr> <tr> <td data-bbox="440 1232 553 1312">PM10</td> <td data-bbox="553 1232 1468 1312">Good combustion practice; Use of natural gas or LPG if natural gas is not available.</td> </tr> <tr> <td data-bbox="440 1312 553 1392">PM2.5</td> <td data-bbox="553 1312 1468 1392">Good combustion practice; Use of natural gas or LPG if natural gas is not available.</td> </tr> <tr> <td data-bbox="440 1392 553 1419">CO</td> <td data-bbox="553 1392 1468 1419">400 ppmvd at 3% O₂, Burner technology controlling NOx as a priority</td> </tr> </table> <p>*Note: Despite this BACT determination being done for both natural gas and LPG it was discovered that natural gas and LPG do not conform to the same standards and therefore this BACT determination is not applicable to LPG units.</p> <p><u>RULE REQUIREMENTS:</u> Rule 414 - Water Heaters, Boilers And Process Heaters Rated Less Than 1,000,000 BTU Per Hour LPG units are exempt from standards.</p> <p>Rule 411 - NOx from Boilers, Process Heaters and Steam Generators For units with a rating of ≥ 1 MMBtu/hr to < 2 MMBtu/hr fired on natural gas or LPG. 30 ppmvd of NOx corrected to 3% O₂ 400 ppmvd of CO corrected to 3% O₂</p>	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr		VOC	Good combustion practice; Use of natural gas or LPG if natural gas is not available.	NOx	Pool/spa heaters: 55 ppmvd at 3% O ₂ All other boilers/heaters: 20 ppmvd at 3% O ₂	SOx	Good combustion practice; Use of natural gas or LPG if natural gas is not available.	PM10	Good combustion practice; Use of natural gas or LPG if natural gas is not available.	PM2.5	Good combustion practice; Use of natural gas or LPG if natural gas is not available.	CO	400 ppmvd at 3% O ₂ , Burner technology controlling NOx as a priority
For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr															
VOC	Good combustion practice; Use of natural gas or LPG if natural gas is not available.														
NOx	Pool/spa heaters: 55 ppmvd at 3% O ₂ All other boilers/heaters: 20 ppmvd at 3% O ₂														
SOx	Good combustion practice; Use of natural gas or LPG if natural gas is not available.														
PM10	Good combustion practice; Use of natural gas or LPG if natural gas is not available.														
PM2.5	Good combustion practice; Use of natural gas or LPG if natural gas is not available.														
CO	400 ppmvd at 3% O ₂ , Burner technology controlling NOx as a priority														

District/Agency	Best Available Control Technology (BACT)/Requirements														
South Coast AQMD	<p><u>BACT</u> Source: SCAQMD BACT Guidelines for Non-Major Polluting Facilities Note: SCAQMD BACT Guidelines do not contain a determination for boilers/heaters 2 MMBtu/hr or less, since these units are not required to obtain a written permit, pursuant to SCAQMD Rule 219.</p> <p><u>SCAQMD Rule 219(b)(2)</u> Written permits are not required for boilers, process heaters, or any combustion equipment that has a rated maximum heat input capacity of 2,000,000 Btu per hour (gross) or less and are equipped to be heated exclusively with natural gas, methanol, liquefied petroleum gas, or any combination thereof.</p> <table border="1" data-bbox="440 680 1468 953"> <thead> <tr> <th colspan="2">For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> </tbody> </table> <p><u>RULE REQUIREMENTS:</u> None</p>	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr		VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr															
VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
Bay Area AQMD	<p><u>BACT</u> Source: BAAQMD BACT Guideline Note: BAAQMD BACT Guidelines do not contain a determination for boilers/heaters 10 MMBtu/hr or less fired exclusively on natural gas or LPG, since these units are not required to obtain a written permit, pursuant to BAAQMD Regulation 2, Rule 1.</p> <p><u>BAAQMD Rule 2-1-114</u> The following equipment is exempt from the, requirements of Sections 2-1-301 and 302 (requirement to obtain an ATC or PTO): (114.1) Boilers, Heaters, Steam Generators, Duct Burners, and Similar Combustion Equipment:</p> <p>1.2 Any of the above equipment with less than 10 million BTU per hour rated heat input if fired exclusively with natural gas (including compressed natural gas), liquefied petroleum gas (e.g. propane, butane, isobutane, propylene, butylenes, and their mixtures), or any combination thereof.</p> <table border="1" data-bbox="440 1577 1468 1850"> <thead> <tr> <th colspan="2">For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> </tbody> </table> <p><u>RULE REQUIREMENTS:</u> None</p>	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr		VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range
For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr															
VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														
CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range														

District/Agency	Best Available Control Technology (BACT)/Requirements																
San Diego County APCD	<p><u>BACT</u> Source: NSR Requirements for BACT Note: SDCAPCD BACT Guidelines do not contain a determination for boilers/heaters 5 MMBtu/hr or less, since these units are not required to obtain a written permit, pursuant to SDAPCD Rule 11.</p> <p><u>SDAPCD Rule 11(d)</u> Any equipment, operation, or process that is listed below in Subsections (d)(1) through (d)(20), and that meets the stated exemption provision, parameter, requirement, or limitation, is exempt from the requirements of Rule 10.</p> <p>(d)(2)(v) Any boiler, process heater, or steam generator with a manufacturer's maximum gross heat input rating of less than 5 million BTU per hour fired exclusively with natural gas and/or liquefied petroleum gas.</p>																
	<table border="1"> <thead> <tr> <th colspan="2">For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> </tbody> </table>	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr		VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range		
	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr																
	VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range															
	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range															
	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range															
	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range															
	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range															
	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range															
	<p><u>RULE REQUIREMENTS:</u> Regulation 4, Rule 69.2.1 – Small Boilers, Process Heaters, and Steam Generators</p>																
<table border="1"> <thead> <tr> <th colspan="3">Emission Limits (Effective on or after March 25, 2010)</th> </tr> <tr> <th rowspan="2">Type of equipment and size, in MMBtu/hr</th> <th>NOx</th> <th>CO</th> </tr> <tr> <th>ppmvd</th> <th>ppmvd</th> </tr> </thead> <tbody> <tr> <td>Units ≥ 0.6 and ≤ 2.0, except as below, fired on gaseous fuel (D)</td> <td>30</td> <td>400</td> </tr> <tr> <td>Units ≥ 0.6 and ≤ 2.0, except as below, fired on liquid fuel</td> <td>40</td> <td>400</td> </tr> <tr> <td>Units < 0.6</td> <td>Rule not applicable</td> <td>Rule not applicable</td> </tr> </tbody> </table>	Emission Limits (Effective on or after March 25, 2010)			Type of equipment and size, in MMBtu/hr	NOx	CO	ppmvd	ppmvd	Units ≥ 0.6 and ≤ 2.0, except as below, fired on gaseous fuel (D)	30	400	Units ≥ 0.6 and ≤ 2.0, except as below, fired on liquid fuel	40	400	Units < 0.6	Rule not applicable	Rule not applicable
Emission Limits (Effective on or after March 25, 2010)																	
Type of equipment and size, in MMBtu/hr	NOx	CO															
	ppmvd	ppmvd															
Units ≥ 0.6 and ≤ 2.0, except as below, fired on gaseous fuel (D)	30	400															
Units ≥ 0.6 and ≤ 2.0, except as below, fired on liquid fuel	40	400															
Units < 0.6	Rule not applicable	Rule not applicable															
<p>(A) This rule does not apply to waste heat recovery boilers. (B) This rule does not apply to Furnaces, kilns, and any combustion equipment where the material being heated is in direct contact with the products of combustion. (C) This rule does not apply to thermal oxidizers and associated waste heat recovery equipment. (D) Gaseous fuel includes LPG.</p>																	

District/Agency	Best Available Control Technology (BACT)/Requirements																											
San Joaquin Valley APCD	<p>BACT Source: SJVUAPCD BACT Guideline Note: SJVUAPCD BACT Guidelines do not contain a determination for boilers 5 MMBtu/hr or less, since these units are not required to obtain a written permit, pursuant to SJUVAPCD Rule 2020.</p> <p><u>SJVUAPCD Rule 2020 §6.0</u> No Authority to Construct or Permit to Operate shall be required for (§6.1) steam generators, steam superheaters, water boilers, water heaters, steam cleaners, and closed indirect heat transfer systems that have a maximum input heat rating of 5,000,000 Btu per hour (gross) or less and is equipped to be fired exclusively with (§6.1.1.1) natural gas, (§6.1.1.2) liquefied petroleum gas, or (§6.1.1.3) any combination of the two.</p> <table border="1" data-bbox="440 762 1468 1037"> <thead> <tr> <th colspan="2">For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range</td> </tr> </tbody> </table>	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr		VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range													
	For units with a rating of 75,000 Btu/hr to < 2 MMBtu/hr																											
	VOC	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range																										
	NOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range																										
	SOx	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range																										
	PM10	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range																										
	PM2.5	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range																										
	CO	N/A – No BACT determinations found in the ≥ 0.075 to <2 MMBtu/hr range																										
	<p>RULE REQUIREMENTS: SJVUAPCD Rule 4308 – Boilers, Steam Generators, and Process Heaters – 0.075 MMBtu/hr to less than 2.0 MMBtu/hr</p>																											
	<table border="1" data-bbox="440 1186 1443 1801"> <thead> <tr> <th colspan="3">Emission Limits (Effective on or after January 1, 2015)</th> </tr> <tr> <th rowspan="3">Type and Size of Unit, in MMBtu/hr</th> <th colspan="2">NOx Limit (corrected to 3% O₂)</th> </tr> <tr> <th>PUC Gas</th> <th>Non-PUC Gas or Liquid</th> </tr> <tr> <th>lb/MMBtu of heat input (ppmvd)</th> <th>lb/MMBtu of heat input (ppmvd)</th> </tr> </thead> <tbody> <tr> <td>Units ≥ 0.075 and ≤ 0.4, except as below</td> <td>0.024 (20)</td> <td>0.093 (77)</td> </tr> <tr> <td>Units > 0.4 and < 2.0, except as below</td> <td>0.024 (20)</td> <td>0.036 (30)</td> </tr> <tr> <td>Instantaneous water heaters ≥ 0.075 and ≤ 0.4</td> <td>0.024 (20)</td> <td>0.093 (77)</td> </tr> <tr> <td>Instantaneous water heaters >0.4 and <2.0</td> <td>0.024 (20)</td> <td>0.036 (30)</td> </tr> <tr> <td>Pool heaters ≥ 0.075 and ≤ 0.4</td> <td>0.068 (55)</td> <td>0.093 (77)</td> </tr> <tr> <td>Pool heaters > 0.4 and < 2.0</td> <td>0.024 (20)</td> <td>0.036 (30)</td> </tr> </tbody> </table>	Emission Limits (Effective on or after January 1, 2015)			Type and Size of Unit, in MMBtu/hr	NOx Limit (corrected to 3% O ₂)		PUC Gas	Non-PUC Gas or Liquid	lb/MMBtu of heat input (ppmvd)	lb/MMBtu of heat input (ppmvd)	Units ≥ 0.075 and ≤ 0.4, except as below	0.024 (20)	0.093 (77)	Units > 0.4 and < 2.0, except as below	0.024 (20)	0.036 (30)	Instantaneous water heaters ≥ 0.075 and ≤ 0.4	0.024 (20)	0.093 (77)	Instantaneous water heaters >0.4 and <2.0	0.024 (20)	0.036 (30)	Pool heaters ≥ 0.075 and ≤ 0.4	0.068 (55)	0.093 (77)	Pool heaters > 0.4 and < 2.0	0.024 (20)
Emission Limits (Effective on or after January 1, 2015)																												
Type and Size of Unit, in MMBtu/hr	NOx Limit (corrected to 3% O ₂)																											
	PUC Gas	Non-PUC Gas or Liquid																										
	lb/MMBtu of heat input (ppmvd)	lb/MMBtu of heat input (ppmvd)																										
Units ≥ 0.075 and ≤ 0.4, except as below	0.024 (20)	0.093 (77)																										
Units > 0.4 and < 2.0, except as below	0.024 (20)	0.036 (30)																										
Instantaneous water heaters ≥ 0.075 and ≤ 0.4	0.024 (20)	0.093 (77)																										
Instantaneous water heaters >0.4 and <2.0	0.024 (20)	0.036 (30)																										
Pool heaters ≥ 0.075 and ≤ 0.4	0.068 (55)	0.093 (77)																										
Pool heaters > 0.4 and < 2.0	0.024 (20)	0.036 (30)																										
<p>For units with a rating of ≥ 0.4 MMBtu/hr and < 2.0 MMBtu/hr: 400 ppmvd of CO corrected to 3% O₂</p>																												

The following control technologies have been identified and are ranked based on stringency:

SUMMARY OF ACHIEVED IN PRACTICE CONTROL TECHNOLOGIES	
VOC	1.No standard [SMAQMD, SCAQMD, SJVUAPCD, SDCAPCD, BAAQMD]
NOx	1. Boilers/heaters < 400,000 Btu/hr: 77 ppmvd at 3% O ₂ Boilers/heaters ≥ 400,000 Btu/hr: 30 ppmvd at 3% O ₂ – [SJVUAPCD] 2. Boilers/heaters < 600,000 Btu/hr: no standard Boilers/heaters ≥ 600,000 Btu/hr: 30 ppmvd at 3% O ₂ – [SDCAPCD] 3. Boilers/heaters < 1 MMBtu/hr: no standard Boilers/heaters ≥ 1 MMBtu/hr: 30 ppmvd at 3% O ₂ – [SMAQMD] 4. No standard – [SCAQMD, BAAQMD]
SOx	1.No standard [SMAQMD, SCAQMD, SJVUAPCD, SDCAPCD, BAAQMD]
PM10	1.No standard [SMAQMD, SCAQMD, SJVUAPCD, SDCAPCD, BAAQMD]
PM2.5	1.No standard [SMAQMD, SCAQMD, SJVUAPCD, SDCAPCD, BAAQMD]
CO	1.Boilers/heaters < 400,000 Btu/hr: no standard All other boilers/heaters: 400 ppmvd at 3% O ₂ – [SJVUAPCD] 2.Boilers/heaters < 600,000 Btu/hr: no standard All other boilers/heaters: 400 ppmvd at 3% O ₂ – [SDCAPCD] 3.Boilers/heaters < 1 MMBtu/hr: no standard All other boilers/heaters: 400 ppmvd at 3% O ₂ – [SDCAPCD] 4.No standard – [SCAQMD, BAAQMD]

The following control technologies have been identified as the most stringent, achieved in practice control technologies:

BEST CONTROL TECHNOLOGIES ACHIEVED		
Pollutant	Standard	Source
VOC	No standard	
NOx	Boilers/heaters < 400,000 Btu/hr: 77 ppmvd at 3% O ₂ Boilers/heaters ≥ 400,000 Btu/hr: 30 ppmvd at 3% O ₂	SJVUAPCD (Rule 4308)
SOx	No standard	
PM10	No standard	
PM2.5	No standard	
CO	Boilers/heaters < 400,000 Btu/hr: no standard All other boilers/heaters: 400 ppmvd at 3% O ₂	SJVUAPCD (Rule 4308)

B. TECHNOLOGICALLY FEASIBLE AND COST EFFECTIVE (Rule 202, §205.1.b.):

Technologically Feasible Alternatives:

Any alternative basic equipment, fuel, process, emission control device or technique, singly or in combination, determined to be technologically feasible by the Air Pollution Control Officer.

The table below shows the technologically feasible alternatives identified as capable of reducing emissions beyond the levels determined to be “Achieved in Practice” as per Rule 202, §205.1.a.

Pollutant	Technologically Feasible Alternative
VOC	Good combustion practices
NO _x	1. Selective Catalytic Reduction (SCR) 2. Flue Gas Recirculation (FGR) with a Low-NO _x burner
SO _x	Good combustion practices
PM ₁₀	Good combustion practices
PM _{2.5}	Good combustion practices
CO	Good combustion practices

Cost Effective Determination

After identifying the technologically feasible control options, a cost analysis is performed to take into consideration economic impacts for all technologically feasible controls identified.

Maximum Cost per Ton of Air Pollutants Controlled

A control technology is considered to be cost-effective if the cost of controlling one ton of that air pollutant is less than the limits specified below (except coating operations):

<u>Pollutant</u>	<u>Maximum Cost (\$/ton)</u>
ROG	17,500
NO _x	24,500
PM ₁₀	11,400
SO _x	18,300
CO	TBD if BACT triggered

Selective Catalytic Reduction:

Typically selective catalytic reduction (SCR) can be used to reduce emissions from larger boilers. SCR requires ammonia or urea for NO_x reduction and units of this size range are typically used in residences and service/commercial applications where storage of these materials is impractical and could pose a health risk. Additionally, SCR is designed for industrial units that run full time and can maintain a temperature that the catalyst requires for NO_x reduction, whereas smaller units are turned on and off throughout the day and cannot maintain the required temperatures. Finally, SCR systems require frequent maintenance for operation which may not be practical in a residential or small service/commercial setting.

District Staff has done an analysis¹ for using SCR on a boiler rated at 20 MMBTU/hr and the cost effectiveness was \$53,084 per ton of NO_x reduced. As the rating of the unit goes down the total emission reduction will decrease while cost will stay relatively equivalent and therefore the cost effectiveness will increase. Therefore, SCR is not only technologically infeasible for this size range of boilers/heaters but it is also not cost effective and is eliminated as a control option. Although this analysis was done for a natural gas boiler it would still apply to LPG boilers/heaters.

Flue Gas Recirculation with a Low-NO_x Burner:

Adding flue gas recirculation (FGR) to a smaller unit would result in minimal additional reductions when paired with a low-NO_x burner, and would cost more than a low-NO_x burner alone. Like SCR,

¹ SMAQMD, "BACT Determination: Boilers/Heaters \geq 5 and $<$ 20 MMBTU/hr fired on natural gas or LPG," June 3, 2015

the system requires frequent maintenance for operation which may not be practical in a residential or small service/commercial setting. The BAAQMD did an analysis of adding FGR to a boiler in the 400,000 to 2,000,000 Btu/hr range in their 2007 Staff Report for Regulation 9, Rule 6 and found that the incremental cost effectiveness of adding FGR over a low-NOx burner is estimated at \$60,000 per ton of NOx reduced. Therefore, FGR added to a boiler/heater with a low-NOx burner is not cost effective and is eliminated as a control option. Despite the analysis being done for natural gas boilers it would still apply to LPG boilers/heaters.

Good Combustion Practice:

Owners/operators of boilers/heaters should be maintaining good combustion practices as part of proper operation of a boiler/heater and requiring good combustion practices to continue would not add any additional costs. Therefore, because these requirements would not add any additional cost it is a valid control option.

C. SELECTION OF BACT:

Because no other technically feasible alternatives are available for the size range of these boilers/heaters BACT for NOx and CO will remain at what is currently achieved in practice. BACT for VOC, SOx, PM10, and PM2.5 will now be considered good combustion practices since this was shown to be feasible.

BACT for Boilers/Heaters ≥ 75,000 Btu/hr and < 2.0 MMBtu/hr Fired on LPG		
Pollutant	Standard	Source
VOC	Good combustion practices	
NOx	Boilers/heaters < 400,000 Btu/hr: 77 ppmvd at 3% O ₂ Boilers/heaters ≥ 400,000 Btu/hr: 30 ppmvd at 3% O ₂	SJVUAPCD (Rule 4308)
SOx	Good combustion practices	
PM10	Good combustion practices	
PM2.5	Good combustion practices	
CO	Boilers/heaters < 400,000 Btu/hr: good combustion practices Boilers/heaters ≥ 400,000 Btu/hr: 400 ppmvd at 3% O ₂	SJVUAPCD (Rule 4308)

D. SELECTION OF T-BACT:

Toxics are in the form of VOCs and particulate matter. Since toxic emission from propane fired boilers in the 2 MMBtu/hr or less size range are so small and the cancer risk is not expected to be anywhere close to 1 in a million cases, T-BACT was not evaluated for this determination.

REVIEWED BY: _____ **DATE:** _____

APPROVED BY: _____ **DATE:** _____