Marconi (Gilbarco) Vapor Vac System Executive Orders — Rule 449 Daily Maintenance Inspection Form

For every day of operation: Print and sign your name. Place a check mark under each column for every component that you find to be free of defects. If you find a defect, mark a "D" in the corresponding column and note the repairs on the bottom of the page.

Month and Year:	Facility Name, Address, Phone Number	Permit Number

Day	Time	Name	Signature	Does the phase I vapor poppet function properly?	Does each nozzle automatic shutoff function correctly?	Are all of the fueling points connected, and none of them open to the atmosphere?	Booted and unbooted nozzles may not be connected to the same vapor pump. Are the nozzles connected to the vapor pump all the same (either booted or unbooted)?	Are any of the vapor holes blocked? If yes, are there less than 3 unblocked holes for Catlow and Emco Wheaton, less than 4 unblocked for OPW 11VAI, or are they all blocked for any	Is the vapor splash guard missing or damaged? For Catlow nozzles, is it split from base to rim? For Emco Wheaton, is 1/4 of the guard or more missing? For Husky, is there a slit 1.5 inches or more, or a hole 3/4 inch or greater? For OPW, is 3/4 or more of the guard damaged or missing?	Compliant dispensing rate? Required repair on dispensing rate greater than ten gallons per minute (10 gpm) or less than the greater of five (5.0) gpm or the limit stated in the EO measured at maximum fuel dispensing.	Are all components certified? Installation or use of any uncertified component is illegal	Is the system complete and installed as certified? Illegal to disconnect any component required to be used in the EO(s) that certified the system	Is the equipment free of all other defects not listed on this form?
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30													
31													

Repairs Needed